CITY OF KELOWNA

MEMORANDUM

Date:

November 17, 2017

File No.:

Z17-0102

To:

Community Planning (TB)

From:

Development Engineering Manager (JK)

Subject:

344 Christleton Ave Lot 7 Plan 3451

RU1 to RU1c

Carriage House

Development Engineering has the following comments and requirements associated with this application. The utility upgrading requirements outlined in this report will be a requirement of this development.

Domestic Water and Fire Protection

Our records indicate that this property is currently serviced with a 13mm water service. The applicant will arrange for the disconnection of existing service and the installation of a new service. The disconnection of the existing small diameter water services and the tie-in of a larger new service can be provided by City forces at the applicant's Cost. The applicant will be required to sign a Third Party Work Order for the cost of the service upgrade. For estimate inquiry's please contact Jason Angus, by email inquiscolor: inquiscolor: lighth-red and inquiscolor: Inquiscolor:

2. Sanitary Sewer

Our records indicate that this property is currently serviced with a 100mm-diameter sanitary sewer service. An inspection chamber (IC) complete with brooks box must be installed on the service at the owner's cost. Service upgrades can be provided by the City at the applicant's cost. **The applicant will be required to sign a Third Party Work Order for the cost of the service upgrade.** For estimate inquiry's please contact Jason Angus, by email jangus@kelowna.ca or phone, 250-469-8783.

3. Development Permit and Site Related Issues

Direct the roof drains onto splash pads.

Driveway access permissible is one (1) per property as per bylaw

4. Electric Power and Telecommunication Services

It is the applicant's responsibility to make a servicing application with the respective electric power, telephone and cable transmission companies to arrange for service apprades to these services which would be at the applicant's cost.

James Kay, P. Eng.

Development Engineering Manager

JÁ