



4460

423

4440

433

4446

4456

1969

4454

4452

4450

4455

BARKLEY RD

Subject Properties Notes:

Rezone a portion of the subject property from RU1 - Large Lot Housing to RU2 - Medium Lot Housing

44

4468

LAND RD

4474

4467

4480

494

4473

488

4477

4486

4479

486

426

4492

4485

484

ELDORADO RD

436

4491

427

431


435

WALKER RD

4523

439

MAP "A" PROPOSED ZONING
File Z18-0047



Subject Property



RU1 to RU2

This map is for general information only.
The City of Kelowna does not guarantee its
accuracy. All information should be verified.

0 15 30 Metres



Rev. Friday, September 14, 2018

CITY OF KELOWNA
MEMORANDUM

SCHEDULE A

This forms part of application
Z18-0047



City of
Kelowna
COMMUNITY PLANNING

Planner
Initials

LK

Date: May 03, 2018
File No.: Z18-0047
To: Community Planning (TH)
From: Development Engineering Manager (JK)
Subject: 4480 Walker Road


RU1 to RU2

Development Engineering has the following comments and requirements associated with this application.

1. General

Road frontage improvements are triggered by this rezoning application. The requirements include curb and gutter, storm drainage system and pavement restoration. Also required is street lighting and the re-location or adjustment of utility appurtenances if required to accommodate the upgrading construction. The cost of this construction is at the applicant's expense.

The proposed redevelopment includes the subject parcel being subdivided into two lots. A subdivision application will require service upgrades that include the installation of additional services. The work will require road cuts and boulevard and pavement restoration. Development Engineering is prepared to defer the requirements of the rezoning to the subdivision stage.


James Kay, P. Eng.
Development Engineering Manager

JA

CITY OF KELOWNA
MEMORANDUM

SCHEDULE

A

This forms part of application

Z18-0047

Planner
Initials

LK



Date: May 03, 2018
File No.: S18-0038
To: Community Planning (TH)
From: Development Engineering Manager (JK)
Subject: Subdivision Application – PLR Requirements

LOCATION: 4480 Wlaker Road
APPLICANT: Thomas Brown
LEGAL: Lot 1 Plan 16858

WORKS AND SERVICES REQUIREMENTS

The City's Development Engineering Department will handle the Works & Services requirements identified below between time of Preliminary Layout Review (PLR) and application for Subdivision Approval. Arrangements for construction must be made before making application for Final Approval of a subdivision plan. The Development Engineering Technologist for this project is Jason Angus. The following Works & Services are required for this subdivision:

1. General

- a. The postal authorities must be contacted to determine whether or not a "community mailbox" will be utilized. Please contact the Canadian Post Corporation, Delivery Services, P.O. Box 2110, Vancouver, B.C. V6B 4Z3 (604) 662-1381 in this regard.

2. Geotechnical Report

- a. Provide a geotechnical report prepared by a Professional Engineer competent in the field of hydro-geotechnical engineering to address the items below: NOTE: The City is relying on the Geotechnical Engineer's report to prevent any damage to property and/or injury to persons from occurring as a result of problems with soil slippage or soil instability related to this proposed subdivision.
 - i. The Geotechnical reports must be submitted to the Development Services Department (Subdivision Approving officer) for distribution to the Development Engineering Branch and Inspection Services Division prior to submission of Engineering drawings or application for subdivision approval.

- ii. Area ground water characteristics, including any springs and overland surface drainage courses traversing the property. Identify any monitoring required.
- iii. Site suitability for development.
- iv. Site soil characteristics (i.e. fill areas, sulphate content, unsuitable soils such as organic material, etc.).
- v. Any special requirements for construction of roads, utilities and building structures.
- vi. Recommendations for items that should be included in a Restrictive Covenant.
- vii. Recommendations for roof drains, perimeter drains and septic tank effluent on the site.
- viii. Any items required in other sections of this document.

3. Water

- a. The property is located within the City of Kelowna service area. The existing 19mm PVC water service will be utilised to service one of the lots.
- b. Provide an adequately sized domestic water and fire protection system complete with individual lot connections. The water system must be capable of supplying domestic and fire flow demands of the project in accordance with the Subdivision, Development & Servicing Bylaw. Provide water calculations for this subdivision to confirm this. Ensure every building site is located at an elevation that ensures water pressure is within the bylaw pressure limits.

4. Sanitary Sewer

- a. The existing 100mm diameter service will be utilised to service one of the proposed lots.
- b. A new sanitary service should be provided at the applicants cost prior to subdivision approval

5. Drainage

- a. The property is located within the City of Kelowna drainage service area. The Subdivision, Development and Servicing Bylaw requires that each lot be provided with an individual connection; however, the City Engineer may permit use of individual ground water disposal systems, where soils are suitable. For on-site disposal of drainage water, a hydrogeotechnical report will be required complete with a design for the disposal method (i.e. trench drain / rock pit). The Lot Grading Plan must show the design and location of these systems for each lot.
- b. The development is required to contain and dispose of site generated storm drainage on the site by installing a ground recharge system designed by the consulting civil engineer. The existing lots do not presently have storm drainage services.

6. Roads

- a. Walker Road frontage must be upgraded to a full urban standard including curb, gutter, fillet pavement, street lights, storm drainage, and adjustment and/or re-location of existing utility appurtenances if required to accommodate this construction.
- b. Lakeland Road frontage must be upgraded to a full urban standard including curb, gutter, fillet pavement, street lights, storm drainage, and adjustment and/or re-location of existing utility appurtenances if required to accommodate this construction.

7. Power and Telecommunication Services and Street Lights

- a. If the existing area is served by overhead wiring, the service connections may be provided overhead provided that there are no new poles required and service trespasses will not be created. If either of these conditions is not satisfied, then underground service will be required for that lot.
- b. Streetlights must be installed on all roads.
- c. Make servicing applications to the respective Power and Telecommunication utility companies. The utility companies are required to obtain the City's approval before commencing construction.
- d. Before making application for approval of your subdivision plan, please make arrangements with Fortis for the pre-payment of applicable charges and tender a copy of their receipt with the subdivision application for final approval.
- e. Re-locate existing poles and utilities, where necessary. Remove aerial trespass (es).

8. Other Engineering Comments

- a. Provide all necessary Statutory Rights-of-Way for any utility corridors required, including those on proposed or existing City Lands.
- b. If any road dedication affects lands encumbered by a Utility right-of-way (such as B.C. Gas, etc.) please obtain the approval of the utility prior to application for final subdivision approval. Any works required by the utility as a consequence of the road dedication must be incorporated in the construction drawings submitted to the City's Development Manager.

9. Design and Construction

- a. Design, construction supervision and inspection of all off-site civil works and site servicing must be performed by a Consulting Civil Engineer and all such work is subject to the approval of the City Engineer. Drawings must conform to City standards and requirements.
- b. Engineering drawing submissions are to be in accordance with the City's "Engineering Drawing Submission Requirements" Policy. Please note the number of sets and drawings required for submissions.


- c. Quality Control and Assurance Plans must be provided in accordance with the Subdivision, Development & Servicing Bylaw No. 7900 (refer to Part 5 and Schedule 3).
- d. A "Consulting Engineering Confirmation Letter" (City document 'C') must be completed prior to submission of any designs.
- e. Before any construction related to the requirements of this subdivision application commences, design drawings prepared by a professional engineer must be submitted to the City's Development Engineering Department. The design drawings must first be "Issued for Construction" by the City Engineer. On examination of design drawings, it may be determined that rights-of-way are required for current or future needs.

10. Servicing Agreements for Works and Services

- a. A Servicing Agreement is required for all works and services on City lands in accordance with the Subdivision, Development & Servicing Bylaw No. 7900. **The applicant's Engineer, prior to preparation of Servicing Agreements, must provide adequate drawings and estimates for the required works.** The Servicing Agreement must be in the form as described in Schedule 2 of the bylaw.
- b. Part 3, "Security for Works and Services", of the Bylaw, describes the Bonding and Insurance requirements of the Owner. The liability limit is not to be less than \$5,000,000 and the City is to be named on the insurance policy as an additional insured.

11. Charges and Fees

- a. Development Cost Charges (DCC's) are payable
- b. Fees per the "Development Application Fees Bylaw" include:
 - i. Survey Monument Fee: **\$50.00** (\$50.00 per newly created lot GST exempt).
 - ii. Survey Monument, Replacement Fee: \$1,200.00 (GST exempt) – only if disturbed.
- c. A hydrant levy charge of **\$250.00** (250.00 per new lot).



James Kay, P.Eng.
Development Engineering Manager