

Schedule I – Site Plan



ATTACHMENT A

This forms part of application
Z19-0024

Planner Initials

City of Kelowna
COMMUNITY PLANNING



CITY OF KELOWNA
MEMORANDUM

Date: February 22, 2019
File No.: Z19-0024
To: Community Planning (KB)
From: Development Engineering Manager (JK)
Subject: 1310 St Paul Street I2 – C7 RCS

The Development Engineering Department has the following comments and requirements associated with this rezoning application. The road and utility upgrading requirements outlined in this report will be a requirement of this development. The Development Engineering Technologist for this project is Jason Angus.

1) Domestic Water and Fire Protection

- a) Property 1310 St Paul Street is currently serviced with a 38mm-diameter water service. The developer's consulting mechanical engineer will determine the domestic, fire protection requirements of this proposed development and establish hydrant requirements and service needs. The applicant will arrange for the removal and disconnection of the existing services and the installation of one new larger service at the applicants cost.
- b) A water meter is mandatory for this development and must be installed inside the building on the water service inlet as required by the City Plumbing Regulation and Water Regulation bylaws. The developer or building contractor must purchase the meter from the City at the time of application for a building permit from the Inspection Services Department, and prepare the meter setter at his cost. Boulevard landscaping, complete with underground irrigation system, must be integrated with the on-site irrigation system
- c) The developer must obtain the necessary permits and have all existing utility services disconnected prior to removing or demolishing the existing structures. The City of Kelowna water meter contractor must salvage existing water meters, prior to building demolition. If water meters are not salvaged, the developer will be invoiced for the meters.

2) Sanitary Sewer

- a) Our records indicate that these properties are currently serviced with a 150mm-diameter sanitary sewer service. The applicant's consulting mechanical engineer will determine the requirements of the proposed development and establish the service needs. Only one service will be permitted for this development. If required, the applicant will arrange for the removal and disconnection of the existing service and the installation of one new larger service at the applicants cost.

3) Storm Drainage

- a) The developer must engage a consulting civil engineer to provide a storm water management plan for this site which meets the requirements of the City Subdivision Development and Servicing Bylaw 7900. The storm water management plan must also include provision of lot grading plans, minimum basement elevations (MBE), if applicable, and provision of a storm drainage service and recommendations for onsite drainage containment and disposal systems

4) Road Improvements

- a) St Paul Street must be upgraded to a full urban standard along the full frontage of this proposed development, including sidewalk, pavement removal and replacement, boulevard landscaping, underground irrigation system, street lighting and re-location or adjustment of utility appurtenances if required to accommodate the upgrading construction.
- b) The Laneway fronting this development will need to be constructed to a SS-C7 standard.

5) Road Dedication and Subdivision Requirements

- a) Grant Statutory Rights of Way if required for utility services.
- b) If any road dedication or closure affects lands encumbered by a Utility right-of-way (such as Hydro, TELUS, Gas, etc.) please obtain the approval of the utility. Any works required by the utility as a consequence of the road dedication or closure must be incorporated in the construction drawings submitted to the City's Development Manager.
- c) 0.75m laneway dedication is needed for this development.

6) Development Permit and Site Related Issues

- a) Direct the roof drains into on-site rock pits or splash pads.
- b) The vehicle access to this site must be from a fully constructed 7.6m laneway.

7) Electric Power and Telecommunication Services

- a) The electrical and telecommunication services to this building must be installed in an underground duct system, and the building must be connected by an underground service. It is the developer's responsibility to make a servicing application with the respective electric power, telephone and cable transmission companies to arrange for these services, which would be at the applicant's cost.

8) Design and Construction

- a) Design, construction supervision and inspection of all off-site civil works and site servicing must be performed by a Consulting Civil Engineer and all such work is subject to the approval of the City Engineer. Drawings must conform to City standards and requirements.
- b) Engineering drawing submissions are to be in accordance with the City's "Engineering Drawing Submission Requirements" Policy. Please note the number of sets and drawings required for submissions.

- c) Quality Control and Assurance Plans must be provided in accordance with the Subdivision, Development & Servicing Bylaw No. 7900 (refer to Part 5 and Schedule 3).
- d) A "Consulting Engineering Confirmation Letter" (City document 'C') must be completed prior to submission of any designs.
- e) Before any construction related to the requirements of this subdivision application commences, design drawings prepared by a professional engineer must be submitted to the City's Works & Utilities Department. The design drawings must first be "Issued for Construction" by the City Engineer. On examination of design drawings, it may be determined that rights-of-way are required for current or future needs.

9) Servicing Agreement for Works and Services


- a) A Servicing Agreement is required for all works and services on City lands in accordance with the Subdivision, Development & Servicing Bylaw No. 7900. The applicant's Engineer, prior to preparation of Servicing Agreements, must provide adequate drawings and estimates for the required works. The Servicing Agreement must be in the form as described in Schedule 2 of the bylaw.
- b) Part 3, "Security for Works and Services", of the Bylaw, describes the Bonding and Insurance requirements of the Owner. The liability limit is not to be less than \$5,000,000 and the City is to be named on the insurance policy as an additional insured.

10) Administration Charge

- a) An administration charge will be assessed for processing of this application, review and approval of engineering designs and construction inspection. The administration charge is calculated as (3.5% of Total Off-Site Construction Cost plus GST).

11) Survey, Monument and Iron Pins

- a) If any legal survey monuments or property iron pins are removed or disturbed during construction, the developer will be invoiced a flat sum of \$1,200.00 per incident to cover the cost of replacement and legal registration. Security bonding will not be released until restitution is made.



James Kay P.Eng.
Development Engineering Manager

JA