

ATTACHMENT

This forms part of application

LL19-0016



City of Kelowna
DEVELOPMENT PLANNING
Planner Initials WM

BNA BREWING
1250 ELLIS ST

GP 2492

RECEIVED

MAY 02 2019

CITY OF KELOWNA
Development Services Department

Reviewed
by City of Kelowna
Inspection Services

BNA BREWING & CO.
BREWERY STORAGE


The MANUFACTURER LOUNGE
has a net floor area of
120 m². The maximum
occupant load shall be
100 persons, based on
1.2 m²/person

BNA Brewing has not
applied for a building
permit. This review is
for occupant load
ONLY.

Areas based on plans
not site verified.

The LOUNGE PATIO
has a net floor area of
75.6 m². The maximum
occupant load shall be
63 persons, based on
1.2 m²/person

NOTE: Ensure proper
approval for exterior
patio is obtained from
City of Kelowna "Real
Estate and Property-
Services" department.
This review is for
occupant load ONLY.



01 SECTION • PATIO RAIL + COUNTER
SCALE 3/8"=1'-0"

forme interior design inc.
250.575.8484
www.formeinc.ca

forme
INTERIOR DESIGN

project		1250 ELLIS STREET MANUFACTURER LOUNGE	
subject		FLOOR PLAN	
no.	revision	scale	date
03.		1" x 17"	3/32"=1'-0"
02.	RE-ISSUE OCC. LOAD		25/04/19
01.	RE-ISSUE LICENSING		27/02/19
project no.		2019 002	sheet size
			drawn TJ
			SP.01