



CITY OF KELOWNA

MEMORANDUM

Date: January 23, 2020
File No.: Z20-0006 Revised
To: Urban Planning (AJ)
From: Development Engineer Manager (JK)
Subject: 3508-3580 Fleet Ct CD15 to C9

Development Engineering has the following comments and requirements associated with this application to obtain a rezone 3508 Fleet Ct. CD15 to C9 Tourist Commercial

The Development Engineering Technologist for this project is Ryan O'Sullivan

1. General

- a) Applicant will be responsible for a TIA for the proposed development and all improvements including construction associated with TIA.

2. Domestic Water and Fire Protection

- a) The property is located within the GEID service area.
- b) Provide an adequately sized domestic water and fire protection system complete with individual lot connections. The water system must be capable of supplying domestic and fire flow demands of the project in accordance with the Subdivision, Development & Servicing Bylaw. Provide water calculations for this subdivision to confirm this.
- c) Ensure every building site is located at an elevation that ensures water pressure is within the bylaw pressure limits. Note: Private pumps are not acceptable for addressing marginal pressure.
- d) Hydrants are to be spaced at 200m but also must be located within 100m of a building.
- e) Design drawings must be reviewed by GEID prior to the City issuing the drawings for construction. Confirmation of their review must be provided to the City.

3. Geotechnical Report

- a) Provide a comprehensive geotechnical report, prepared by a Professional Engineer competent in the field of hydro-geotechnical engineering to address the items below: **NOTE: The City is relying on the Geotechnical Engineer's report to prevent any damage to property and/or injury to persons from occurring as a result of problems with soil slippage or soil instability related to this proposed subdivision.**

The Geotechnical report must be submitted prior to submission of Engineering drawings or application for subdivision approval.

- i. Area ground water characteristics, including any springs and overland surface drainage courses traversing the property. Identify any monitoring required.
- ii. Site suitability for development.
- iii. Site soil characteristics (i.e. fill areas, sulphate content, unsuitable soils such as organic material, etc.).
- iv. Any special requirements for construction of roads, utilities and building structures.
- v. Suitability of on-site disposal of storm water and sanitary waste, including effects upon adjoining lands.
- vi. Slope stability, rock fall hazard and slippage including the effects of drainage and septic tank effluent on the site.
- vii. Identify slopes greater than 30%.
- viii. Top of bank assessment and location including recommendations for property line locations, septic field locations, building setbacks, and ground water disposal locations.
- ix. Recommendations for items that should be included in a Restrictive Covenant.
- x. Any special requirements that the proposed subdivision should undertake so that it will not impact the bank(s). The report must consider erosion and structural requirements.
- xi. Any items required in other sections of this document.
- xii. Recommendations for erosion and sedimentation controls for water and wind.
- xiii. Recommendations for roof drains and perimeter drains.
- xiv. Recommendations for construction of detention or infiltration ponds if applicable.

4. Sanitary Sewer

City of Kelowna's records indicate that this property is connected with 150mm PVC sewer services. The developer's consulting mechanical engineer will determine the development requirements of this proposed development and establish the service needs. Only one service will be permitted for this development. The applicant, at his cost, will arrange for the removal and disconnection of the existing services and the installation of one new larger service if necessary.

5. Storm Drainage

- a. The developer must engage a consulting civil engineer to provide a storm water management plan for the site, which meets the requirements of the City Storm Water Management Policy and Design Manual. The storm water management plan must also include provision of lot grading plan, minimum basement elevation (MBE), if applicable, and recommendations for onsite drainage containment and disposal systems.
 - (a) The developer must engage a consulting civil engineer to provide a storm water management plan for this site which meets the requirements of the City Storm Water Management Policy and Design Manual. The drainage study should indicate the size and location of detention and treatment facilities.
 - (b) Provide a Lot Grading Plan.
- b. There is a possibility of a high water table or surcharging of storm drains during major storm events. This should be considered in the design of the onsite system.
- c. Due to possible hydrogen carbon contaminants a OSG system must be installed before out let to City of Kelowna Storm System.

6. Road Improvements

- (a) Extend Sidewalk around Fleet court Cul-de-sac to South Property line.
- (b) Fleet Court frontages must be landscaped to City of Kelowna By-law standards. Irrigation system to be tied into 3580-3508 Fleet court water systems.
- (c) Second access and cross access agreement to be provided for 3508 Fleet Ct. into 5505-5507 Airport Way.

7. Electric Power and Telecommunication Services

- a) All proposed service connections are to be installed underground. It is the developer's responsibility to make a servicing application with the respective electric power, telephone and cable transmission companies to arrange for these services, which would be at the applicant's cost.
- b) Re-locate existing utilities, where necessary

8. Design and Construction

- (a) Design, construction supervision and inspection of all off-site civil works and site servicing must be performed by a Consulting Civil Engineer and all such work is subject to the approval of the City Engineer. Drawings must conform to City standards and requirements.
- (b) Engineering drawing submissions are to be in accordance with the City's "Engineering Drawing Submission Requirements" Policy. Please note the number of sets and drawings required for submissions.
- (c) Quality Control and Assurance Plans must be provided in accordance with the Subdivision, Development & Servicing Bylaw No. 7900 (refer to Part 5 and Schedule 3).
- (d) A "Consulting Engineering Confirmation Letter" (City document 'C') must be completed prior to submission of any designs.
- (e) Before any construction related to the requirements of this subdivision application commences, design drawings prepared by a professional engineer must be submitted to the City's Development Engineering Department. The design drawings must first be "Issued for Construction" by the City Engineer. On examination of design drawings, it may be determined that rights-of-way are required for current or future needs.

9. Servicing Agreements for Works and Services

- (a) A Servicing Agreement is required for all offsite works and services on City lands in accordance with the Subdivision, Development & Servicing Bylaw No. 7900. The applicant's Engineer, prior to preparation of Servicing Agreements, must provide adequate drawings and estimates for the required works. The Servicing Agreement must be in the form as described in Schedule 2 of the bylaw.
- (b) Part 3, "Security for Works and Services", of the Bylaw, describes the Bonding and Insurance requirements of the Owner. The liability limit is not to be less than \$5,000,000 and the City is to be named on the insurance policy as an additional insured.

10. Other Engineering Comments


- (a) Provide all necessary Statutory Rights-of-Way for any utility corridors as required.
- (b) If any road dedication affects lands encumbered by a Utility right-of-way (such as Fortis, etc.) please obtain the approval of the utility prior to application for final subdivision approval. Any works required by the utility as a consequence of the road dedication must be incorporated in the construction drawings submitted to the City's Development Manager.

11. Development Permit and Site Related Issues

- (a) Access and Manoeuvrability
 - (i) MSU design vehicle must be able to manoeuvre without backing onto Fleet Court.

12. Charges and Fees

- a) Development Cost Charges (DCC's) are payable.
- b) Fees per the "Development Application Fees Bylaw" include:
 - i) Survey Monument, Replacement Fee: \$1,200.00 (GST exempt) – only if disturbed.
 - ii) Engineering and Inspection Fee: 3.5% of construction value (plus GST).



James Kay, P. Eng.
Development Engineering Manager

RO