



DUNNENZIES 4.0



- SERVICES SHALL BE CONCEALED IN WALLS, CEILING, AND FLOORS.
- CONTROL BOXES AND WIRING TO BE FLUSHED MOUNTED AND CONCEALED IN WALLS.
- ALL SUB-TRADES WILL REVIEW DRAWINGS AND SPECIFICATIONS, TO VERIFY ROUGH-IN DATA, PRIOR TO COMMENCING WORK.
- A MINIMUM CLEAR OPENING OF 3'-0" X 7'-0" IS REQUIRED FOR ENTRY OF EQUIPMENT, UNLESS OTHERWISE NOTED.
- FLOOR PANS, DEPRESSIONS, GROUT AND INSTALLATION BY GENERAL CONTRACTOR IN CONJUNCTION WITH FES.
- FINAL DUCT CONNECTION AND AIR BALANCING BY OTHERS UNLESS OTHERWISE NOTED.
- EXHAUST SYSTEMS TO CONFORM TO NFPA96 AND LOCAL CODES.
- CONSULT H.V.A.C. ENGINEER FOR MAKE-UP AIR REQUIREMENTS.

DRAWING TITLE: SEATING LAYOUT

NO.	DATE	REVISION

DATE ISSUED: 04-05-24
 DRAWN BY: LB
 SCALE: N.T.S.
 DRAWING NUMBER:

FD